



- NOTES:
- FOUNDATION DESIGN BASED ON 4000 PSF SOIL BEARING CAPACITY. IF OTHER CONDITIONS EXIST, FOUNDATION WILL HAVE TO BE REDESIGNED.
 - BOTTOM OF FOUNDATION MUST BE BELOW FROST LINE AND BEAR ON UNDISTURBED SOIL.
 - | | | |
|---------------|------------------|---------------------------------|
| SHELTER WIDTH | FOUNDATION WIDTH | FOUNDATION LENGTH |
| 8' WIDE | 7'3" WIDE | OUTSIDE EDGE TO OUTSIDE EDGE |
| 10' WIDE | 9'3" WIDE | SUBTRACT 9" FROM SHELTER LENGTH |
| 12' WIDE | 10'11" WIDE | |
 - CONCRETE TO BE 3000 PSI.
 - REBAR $F_y = 60,000$ PSI.

R7	GENERAL REVISIONS.	12-19-95	RAP
ROHN THIS DRAWING IS THE PROPERTY OF ROHN. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE INDICATED HEREON. NO PART OF THIS DRAWING IS TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT OUR WRITTEN CONSENT.			
TITLE CONCRETE SHELTER FOUNDATION PLAN			
DRAWN BY	RAP	DATE	4-9-91
SCALE	NONE		
CHKD BY	CLP	DATE	4-9-91
APPROV BY ENG.	CLP	DATE	4-9-91
APPROV BY PROD.		DWG NO.	B910597 R7