



INSTRUCTIONS

- 1) SPACE CABLE CLAMPS OR FIST GRIPS AT CABLE DIA. APART. (U-BOLT SHALL BEAR ON DEAD END)
- 2) UNWIND ONE STRAND FROM DEAD CABLE, APPLY SERVING TOOL, AND WRAP 6 TIMES AROUND.
- 3) UNWIND SECOND STRAND FROM DEAD CABLE, APPLY SERVING TOOL, AND WRAP 6 TIMES AROUND. REPEAT WITH EACH REMAINING STRAND.
- 4) COMPLETED CONNECTION CLIPPED AND SERVED EACH STRAND WOUND AROUND GUY CABLE SIX TIMES.
- 5) RETIGHTEN CABLE CLAMPS AFTER INITIAL TENSION HAS BEEN APPLIED.

| | | | |
|----------------|------------------|---------|----|
| NO. | DESCRIPTION | DATE | BY |
| R ₃ | ADDED FIST GRIPS | 9-25-78 | BR |
| R ₂ | ADDED NOTE | 7-6-76 | OK |
| R ₁ | REDRAWN | 1-3-75 | WR |

| REVISIONS | |
|---|-------------|
| NO. | DESCRIPTION |
| ROHN® MANUFACTURING DIVISION OF | |
| TITLE CLIPPED AND SERVED GUY CABLE CONNECTION INSTRUCTIONS | |

| | | | | |
|--------------|--------------|---|--|-------------------|
| SCALE: NONE | | MATERIAL: FINISH: | | FILE NO.: |
| DATE: 1-3-75 | DATE: 1-7-75 | UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE GIVEN IN INCHES. | | DWG. NO. B-690712 |
| DRW. BY: WR | DATE: 1-7-75 | TOLERANCES UNLESS OTHERWISE SPECIFIED: | | |
| CHK. BY: OK | DATE: 1-7-75 | DEC. ± | | |
| APP. BY: BR | DATE: 1-7-75 | ANGLES ± | | |

- 3. CABLE CLAMPS OR FIST GRIPS REQD. PER TURNBACK
- 4. CABLE CLAMPS OR FIST GRIPS REQD. PER TURNBACK
- 5. CABLE CLAMPS OR FIST GRIPS REQD. PER TURNBACK

- 3/16 HS & EHS
- 1/4 HS & EHS
- 5/16 HS & EHS
- 3/8 HS & EHS
- 7/16 HS
- 1/2 EHS
- 1/2 HS & EHS
- 9/16 EHS
- 5/8 EHS
- 3/4 EHS

NOTE: DUE TO VARIABLES INVOLVED IN ROOF AND OTHER INSTALLATIONS, IT SHALL BE THE CUSTOMER'S OR INSTALLER'S RESPONSIBILITY TO PROVIDE STRUCTURALLY ADEQUATE SUPPORTS FOR PIER & ANCHOR CONNECTIONS. IT MAY ALSO BE NECESSARY FOR THE CUSTOMER OR INSTALLER TO SECURE THE SERVICE OF A LOCAL ENGINEER TO DETERMINE THAT INSTALLATION COMPLIES WITH LOCAL BUILDING CODES.

PRINTED IN U.S.A.

GAF 880-250 2-72 48191